

**Howard Community College**

ITB: Facility Renewal Project – Mechanical Pipe Replacement

Bid Number: 22-001

ITB Opening Date: August 9, 2021

**ADDENDUM No. 4**

*Q1. Do the As-built plans received in Addendum #3 reflect the full extent of the pipe that gets replaced?*  
HCC has provided all current as-builts that the college has available. The heating and cooling lines to be replaced begin at the demarcation point in Clark Library and extend from that point through Howard Hall (in tunnel) to the point in McCuan Hall that was shown during the walk through. It is the contractor's responsibility to verify line size and route.

*Issued July 27, 2021*